



Certificate of Compliance

Certificate: 2011806

Master Contract: 242437

Project: 2303538

Date Issued: May 20, 2010

Issued to: **Pietro Fiorentini**

**Via Enrico Fermi 8/10
Areugnano, Vicenza 36057
Italy
Attention: Rick Schneider**

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Richard Clark

Issued by: Richard Clark

PRODUCTS

CLASS 3331 85 - REGULATORS (GAS) - Line Pressure-Certified to U.S. Standards

CLASS 3331 82 - REGULATORS (GAS) - Gas Appliance Pressure-Certified to U.S. Standards

CLASS 3331 02 - REGULATORS (GAS) - Gas Appliance Pressure

CLASS 3331 05 - REGULATORS (GAS) - Line Pressure

Regulator Class II with maximum outlet pressure of 2 PSIG

Regulator Class I with maximum outlet pressure of 1/2 PSIG

Appliance regulators are approved for pilot flow conditions

Model	Size	Maximum Inlet	Maximum Inlet
		(Class I, Class II & Appliance)	(Class I, Class II & Appliance)
Number	Inches	Pressure (PSIG)	Pressure (PSIG)



Certificate: 2011806

Master Contract: 242437

Project: 2303538

Date Issued: May 20, 2010

30051	½	5	2
30052	¾	5	2
30053	1	5	2
30150	½	5	2
30151	¾	5	2
30152	1	5	2
30153	1 ¼	5	2
30154	1 ½	5	2
30155	2	5	2
30157/F	3	5	2
30158/F	4	5	2

Models with Slam Shut OPCO

32051	½	5
32052	¾	5
32053	1	5

Models with OPD Regulator

30051DC	1/2	5
30052DC	3/4	5
30053DC	1	5
30150DC	1/2	5
30151DC	3/4	5
30152DC	1	5
30153DC	1 1/4	5



Certificate: 2011806

Master Contract: 242437

Project: 2303538

Date Issued: May 20, 2010

30154DC	1 1/2	5
30155DC	2	5
30157DC/F	3	5
30158DC/F	4	5

APPLICABLE REQUIREMENTS

ANSI Z21.80a / CSA 6.22a-2005 Line Pressure Regulators

ANSI Z21.18 / CSA 6.3-2007 Gas Appliance Pressure Regulators